



November 18, 2022

Mr. Bernie Bowers
Operations Supervisor
Wyandotte Public Schools
639 Oak Street
Wyandotte, Michigan 48192
Bowersb@wy.k12.mi.us

RE: **AEG Project # AE220046**
Lead Drinking Water Sampling
Childhood Center

Dear Mr. Bowers:

Pursuant to the request of Wyandotte Public Schools, Arch Environmental Group, Inc. (AEG) collected three (3) representative first draw drinking water lead samples on November 5, 2022, at the Childhood Center during a normal usage period.

General Information about Lead

There is no federal law requiring testing of drinking water in schools and childcare facilities, except for those that have and/or operate their own public water system and therefore are subject to comply with the Safe Drinking Water Act (SDWA). Drinking water programs are conducted on a voluntary basis.

Lead enters drinking water:

1. *Through Corrosion*
Most lead gets into drinking water after the water leaves the local well or treatment plant and comes into contact with plumbing materials containing lead. These include lead pipe and lead solder (commonly used until 1986) as well as faucets, valves, and other components made of brass. The physical/chemical interaction that occurs between the water and plumbing is referred to as corrosion. The extent to which corrosion occurs contributes to the amount of lead that can be released into the drinking water.
2. *Faucet Aerators*
Many taps that are used to provide water for human consumption have an aerator as part of the faucet assembly. Screens are not intended to remove contaminants in the water but may trap sediment or debris as water passes through the faucet. Lead bearing sediment may end up in drinking water from physical corrosion of leaded solder and can build up in the aerator over time.
3. *Galvanized Piping*
Additionally, galvanized pipes are old iron pipes that were installed in many homes built before the 1960s. Over many years, old corrosion scales build up inside the walls of galvanized pipes. These pipes can cause discolored water and pressure issues. Galvanized pipes can also release lead in water if you have or ever have had a lead service line.


4. *Brass Pipes, Faucets Fittings and Valves*

Brass used prior to 2014 to deliver drinking water can contribute to lead levels at the tap. Lead has long been used in the foundry process to make brass castings pressure tight. Lead is sometimes added in concentrations of about 2%.

Action Levels

The Lead and Copper Rule (LCR) is a treatment technique rule. Instead of setting a maximum contaminant level (MCL) for lead or copper, the rule requires public water systems to take certain actions to minimize lead and copper in drinking water. The Action Level for lead is 15 ug/L (15 ppb). Beginning January 1, 2025, the action level for lead in the State of Michigan will be lowered to 12 ug/L (12 ppb). In August 2016, the Michigan Department of Environment, Great Lakes, and Energy (EGLE) recommended school districts use the contaminate level goal of 5 ug/L (5 ppb). Finally, in May of 2019, The American Academy of Pediatrics called for new federal standards to ensure water lead concentrations do not exceed 1 ug/L (1 ppb). For this sampling event, the district shall utilize 12 ug/L (ppb) as the Action Level.

Common Drinking Water Outlets



Collection Procedures

All water samples were collected utilizing 250 milliliter (mL) sample bottles as recommended in the August 1, 2016, Version 3.0 “EGLE Guidance on Drinking Water Sampling for Lead and Copper at Schools and Daycares on Community Water Supplies”. Sample results are representative of the specific fixture sampled and do not represent the distribution system or other fixtures.

First Draw Sampling:

AEG collected first draw samples. A first draw is the water that is the first to come out of the tap after the period of 8-24 hours of inactivity.

All locations sampled identified lead below the 12 ug/L Action Level. No further action is recommended at this time.

If you have any questions regarding the report, please feel free to contact the cleanWATER team at (248) 426-0165 [office].

Sincerely,

Arch Environmental Group, Inc.
Environmental Services

A handwritten signature in black ink, appearing to read 'Victoria Heed', written in a cursive style.

Victoria Heed
Consultant, D-5 Waterworks Operator #22152

Attachments: Results Table
 Analytical Results & Chain of Custody



Wyandotte Public Schools
 Drinking Water Analysis
 Project Number: AE220046

Childhood Center									
Date of Sampling: November 5, 2022									
Sampler: Zachary Fortin									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Child-01	Hallway Across from Food Service, Left Water Cooler	WC	10:25 AM	12	ND ³	N	N	Unknown	Initial First Draw
Child-02	Hallway Across from Food Service, Right Water Cooler	WC	10:27 AM	12	ND	N	N	Unknown	Initial First Draw
Child-04	Second Floor, Hallway Between Restrooms, Right Water Cooler	WC	10:33 AM	12	ND	N	N	Unknown	Initial First Draw

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler
 2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf
 3) ND = Non-Detected at Reported Detection Limit of 1 ug/L

November 16, 2022

Arch Environmental Group
37720 Interchange Dr.
Farmington Hills, MI 48335

Subject: Childhood Center IFD
AE220046 - WPS

Dear Ms. Sendra :

Thank you for making Brighton Analytical, L.L.C. your laboratory of choice. Attached are the results for the samples submitted on 11/09/2022 for the above mentioned project. NELAP/TNI Accredited Analysis and EGLE Drinking Water Certified Analysis will be identified in their respective reporting formats. Hard copies can be supplied at your request for a fee of \$20.00 per copy.

The invoice for this project will be emailed separately. If you have any questions concerning the data or invoice, please don't hesitate to contact our office. We welcome your comments and suggestions to improve our quality systems. Please reference Brighton Analytical, L.L.C. Project ID 85907 when calling or emailing. We thank you for this opportunity to partner with you on this project and hope to work with you again in the future.

Sincerely,
Brighton Analytical, L.L.C.



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 EGLE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 11/05/2022 10:25
 Submit Date/Time: 11/09/2022 13:40
 Report Date: 11/16/2022

Arch Environmental Group
 37720 Interchange Dr.
 Farmington Hills, MI 48335

BA Project # **85907**
 BA Sample ID **CS03243**

Project Name: **Childhood Center IFD**
 Project Number: **AE220046 - WPS**
 Sample ID: **Child-01 Hallway Across Food Service Left Water Cooler**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analyst	Analysis Date
Drinking Water Metal Analysis								
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:44	LT	11/15/2022

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve EGLE designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 

 Date 11/16/2022



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 EGLE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 11/05/2022 10:27
 Submit Date/Time: 11/09/2022 13:40
 Report Date: 11/16/2022

Arch Environmental Group
 37720 Interchange Dr.
 Farmington Hills, MI 48335

BA Project # **85907** Project Name: **Childhood Center IFD**
 BA Sample ID **CS03244** Project Number: **AE220046 - WPS**
 Sample ID: **Child-02 Hallway Across Food Service Right Water Cooler**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analyst	Analysis Date
Drinking Water Metal Analysis								
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:46	LT	11/15/2022

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve EGLE designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 11/16/2022



Brighton Analytical LLC
 2105 Pless Drive
 Brighton, Michigan 48114
 Phone: (810)229-7575 (810)229-8650
 e-mail: bai-brighton@sbcglobal.net
 EGLE Certified #9404
 NELAC Accredited #176507

Sample Date/Time: 11/05/2022 10:33
 Submit Date/Time: 11/09/2022 13:40
 Report Date: 11/16/2022

Arch Environmental Group
 37720 Interchange Dr.
 Farmington Hills, MI 48335

BA Project # **85907**
 BA Sample ID **CS03245**

Project Name: **Childhood Center IFD**
 Project Number: **AE220046 - WPS**
 Sample ID: **Child-04 Second Floor Hallway Between Restrooms Right WC**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analyst	Analysis Date
Drinking Water Metal Analysis								
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:48	LT	11/15/2022

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve EGLE designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
 Date 11/16/2022

REPORT RESULTS TO:
Arch Environmental Group

Attn: Jenna Sendra
PHONE:
FAX: labs@archenvgroup.com
EMAIL:

Sample received within holding time? yes no
Temperature of samples °C:
pH verified in login? yes no
Headspace/bubbles in VOA's? yes no
Sample containers and COC match? yes no

BILLING ADDRESS (IF REQUIRED)

Brighton ID #	Sample Description 35 Characters Limit	If RUSH approved by:		Container Type & Quantity								Sample Matrix	Lead	
		Time	Date	VOA'S (PRES)	VOA'S (UNPRES)	HDPE UNPRESERVED	HDPE HNO ₃ FILTERED	HDPE HNO ₃ UNFILTERED	HDPE H ₂ SO ₄	AMBER GLASS	AMBER GLASS (PRESERVE/NOT PRESERVE)			STERILIZED BACTERIA
1503243	Child-01 Hallway Across from Food Service, Left Water Cooler	10:25	1/15/2022					X					DW	X
2)	Child-02 Hallway Across from Food Service, Right Water Cooler	10:27	1/15/2022					X					DW	X
3)	Child-04 Second Floor, Hallway Between Restrooms, Right Water Cooler	10:33	1/15/2022					X					DW	X
4)													DW	
5)													DW	
6)													DW	
7)													DW	
8)													DW	
9)													DW	
10)													DW	

Drinking Water:
Fax to LCHD? yes no
Chlorinated Water Supply? yes no
MCL Failure yes no
Client Notified (date/time/initials):

Special Instructions:		Please fill out the Chain of Custody completely and review. Incorrect or incomplete information will result in a "hold" on all analyses.					
Trans. #	RELINQUISHED BY:	RECEIVED BY:	DATE:	TIME:	RECEIVED BY:	DATE:	TIME:
1	Jenna Sendra	KK [Signature]	11/9/22	12:18	[Signature]	11/9/22	1:40
2							

BA PROJECT #: 85907

ABBREVIATIONS FOR SAMPLE MATRIX
S = Solid
L = Liquid
DW = Drinking H₂O
WW = Wastewater
O = Oil
P = Wipe
A = Air (Tedlar Bag)
F = Filter
T = Tube
M = Misc
GW = Groundwater
SW = Surface Water

Brighton Analytical, L.L.C.™
2105 Pless Drive
Brighton, MI 48114
Phone: 810-229-7575 Fax: 810-229-8650

PROJECT NAME: Childhood Center IFD
PROJECT NUMBER: AE220046

P.O. NUMBER: Wyandotte Public Schools

Sample collected by: Zachary Fortin

REQUESTED TURNAROUND: (X BOX WITH TAT NEEDED)
Default TAT Standard: 5 - 10 Business days
RUSH: 1 Business day (verify with lab)
RUSH: 2 Business days
RUSH: 3 Business days
RUSH SURCHARGE
1 DAY=3X COST 2 DAY = 2X COST 3 DAY = 1.5X COST

Sample Description
35 Characters Limit

Time
Date

VOA'S (PRES)
VOA'S (UNPRES)

HDPE UNPRESERVED
HDPE HNO₃ FILTERED
HDPE HNO₃ UNFILTERED
HDPE H₂SO₄

AMBER GLASS
AMBER GLASS (PRESERVE/NOT PRESERVE)
STERILIZED BACTERIA
MEOH Preserved:
(Field or Lab Preserved)

Sample Matrix
Lead

Drinking Water:
Fax to LCHD? yes no
Chlorinated Water Supply? yes no
MCL Failure yes no
Client Notified (date/time/initials):

Special Instructions:

Trans. # **RELINQUISHED BY:** **RECEIVED BY:** **DATE:** **TIME:** **RECEIVED BY:** **DATE:** **TIME:**



BRIGHTON ANALYTICAL, LLC

QUALITY ASSURANCE/QUALITY
CONTROL

ICP-MS

METHOD 200.8/6020

REPRESENTATIVE BATCH PRECISION AND ACCURACY QUALITY CONTROL SUMMARY

Analysis Date: 11/15/2022 Standard ID: 101722 H2O Batch: 11/14/2022 B1
 Matrix Spike Lab ID: CS03242 Matrix: Total Analyst: LT

Metals	Matrix Spike - Precision *			Matrix Spike - Accuracy**				Miscellaneous***		
	Matrix Spike (ug/L)	Matrix Spike Dup (ug/L)	RPD (%)	Spk Conc (ug/L)	MS Recovery (%)	MSD Recovery (%)	Sample Conc (ug/L)	Method Blk (ug/L)	LCS-Method STD (%)	Ind. Std. (%)
Lead	1094	984	10.6	1000	109.4	98.4	0	<1	106.7	109.9

* Matrix spike precision range +/- 20% RPD

** Matrix spike accuracy range +/- 20% recovery

*** LCS accuracy range +/- 15% recovery / Ind std accuracy range +/- 10% recovery

Comments: _____